

Feasibility Study for water recycling technologies

1. Overview

Namibia is among the most arid countries in southern Africa. Though it receives an average of 360mm of rainfall each year, 83 percent of this water evaporates immediately after rainfall. Another 14 percent goes towards vegetation, and one percent supplies the ground water in the region, thus leaving merely two percent for surface use. Despite these staggering statistics, Windhoek, Namibia's capital, endures the most severe environmental conditions of the nation. the nearest reliably running river (the Okavango River) is approximately 700 km away.

Limited water resources are still an issue in Namibia, due to its ever-growing population. An increase in demand and the misuse of water exacerbates this water scarcity issue. To mitigate this issue, the Country's most feasible option is to augment the percentage of reclaimed water.

2. Introduction

Direct reclamation became a reality in 1968 In Windhoek, Namibia when severe water shortages were experienced before the extension of the state water supply scheme could be completed. The first reclamation plant started to operate in 1968 with a capacity of 4,800 m³/d. Since then the reclamation process has undergone various changes of improvement (Haarhoff and van der Merwe, 1995). Investigations conducted during 1991 recommended that with minor changes to the plant, the capacity could be extended and the final water quality improved (Haarhoff, 1991). During a drought in 1992, where state supplies could not deliver the required quantity, the then existing plant was upgraded and extended to an interim capacity of 14,000 m³/d with the intention of ultimately reclaiming 21,000 m³/d. During another severe drought in 1997 it was however decided to build a new reclamation plant at an adjacent site to the Old Goreangab Reclamation Plant. During the period 1992 to 1998, all the components of the reclamation system were reviewed and re-analyzed and incorporated into the design of a new reclamation plant. In September 2002 the New Goreangab Reclamation Plant (NGRP) was commissioned. The old plant is now treating effluents for irrigation of parks and sports fields.

3. Feasibility Study

3.1 Otjiwarongo

Otjiwarongo is situated in central-north Namibia on the TransNamib railway. It is the biggest business center for Otjozondjupa Region. It is located on the B1 road and its links between Windhoek, the Golden Triangle of Otavi, Tsumeb and Grootfontein, and Etosha National Park. It is one of Namibia's fast-growing towns, with a neat and peaceful quality environment, and many excellent facilities including supermarkets, banks, lodges and hotels. Some of Namibia's best-known private game farms and nature reserves are located in and around the town.

In many of Otjiwarongo's townships residents live in shacks. In 2020 the city had a total of 6,251 of these informal housing structures, accommodating more than 50,000 inhabitants, more than the most recent (2011) census reported as total population figure.

In this project, we are likely to focus on the informal settlement area for water supply if any other conditions for the construction of water infra structure is affordable. Because in many developing countries, the accessibility for water related infra structure is worse than the one of formal settlement area.

Otjiwarongo has a semi-arid climate with hot summers and mild winters. The average annual precipitation is 457 mm.

Table 1. Climate data for Otjiwarongo

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year |
|----------------------|------|------|------|-----|-----|-----|-----|------|-----|-----|------|-----|------|
| Ave (C) | 32 | 30 | 29 | 29 | 27 | 24 | 24 | 27 | 31 | 32 | 33 | 34 | 29 |
| Daily(C) Mean | 24.5 | 23.5 | 22.5 | 21 | 18 | 15 | 15 | 17.5 | 22 | 23 | 24.5 | 25 | 21.0 |
| Average Low | 17 | 17 | 16 | 13 | 9 | 6 | 6 | 8 | 13 | 14 | 16 | 16 | 13 |




Figure 1. Map Otjiwarongo

Table 2. Water demand in Otjiwarongo (20 years)
unit : ton

| FY | January | February | March | April | May | June | July | August | September | October | November | December | Year | Ave/month | Ave/day |
|-------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|------------------|----------------|--------------|
| 1999 | 94,612 | 106,887 | 127,095 | 147,709 | 123,979 | 122,202 | 112,119 | 121,761 | 131,647 | 140,466 | 157,158 | 95,121 | 1,480,756 | 123,396 | 4,046 |
| 2000 | 157,322 | 96,896 | 128,983 | 88,682 | 107,641 | 106,717 | 108,717 | 126,330 | 116,041 | 129,635 | 125,718 | 172,124 | 1,464,806 | 122,067 | 4,002 |
| 2001 | 168,728 | 136,700 | 86,627 | 95,471 | 102,900 | 102,900 | 98,953 | 105,412 | 129,506 | 110,727 | 149,568 | 82,309 | 1,369,801 | 114,150 | 3,743 |
| 2002 | 155,854 | 127,901 | 123,627 | 116,162 | 114,958 | 108,663 | 103,115 | 133,923 | 120,657 | 108,931 | 169,962 | 95,618 | 1,479,371 | 123,281 | 4,042 |
| 2003 | 170,924 | 111,613 | 102,730 | 126,794 | 119,501 | 131,518 | 109,270 | 156,969 | 104,133 | 161,684 | 144,745 | 94,151 | 1,534,032 | 127,836 | 4,191 |
| 2004 | 151,246 | 109,040 | 105,523 | 121,993 | 106,284 | 117,367 | 128,329 | 126,957 | 100,987 | 136,431 | 160,260 | 98,326 | 1,462,743 | 121,895 | 3,997 |
| 2005 | 146,111 | 87,125 | 90,292 | 118,805 | 105,160 | 139,464 | 109,027 | 122,121 | 156,036 | 115,884 | 117,413 | 129,689 | 1,437,127 | 119,761 | 3,927 |
| 2006 | 105,057 | 104,973 | 120,248 | 107,321 | 94,623 | 96,590 | 118,157 | 108,603 | 122,137 | 135,607 | 127,723 | 121,294 | 1,362,333 | 113,528 | 3,722 |
| 2007 | 177,673 | 94,652 | 88,165 | 112,861 | 112,137 | 115,987 | 119,852 | 136,802 | 106,151 | 135,873 | 110,412 | 139,087 | 1,449,652 | 120,804 | 3,961 |
| 2008 | 127,834 | 83,206 | 72,252 | 90,082 | 107,423 | 126,822 | 126,614 | 89,633 | 123,445 | 123,034 | 117,930 | 108,037 | 1,296,312 | 108,026 | 3,542 |
| 2009 | 104,241 | 107,640 | 118,230 | 99,752 | 110,059 | 120,488 | 85,217 | 120,433 | 121,004 | 121,004 | 128,014 | 109,257 | 1,345,338 | 112,112 | 3,676 |
| 2010 | 117,290 | 90,413 | 91,632 | 109,988 | 89,540 | 101,075 | 88,658 | 141,064 | 120,090 | 91,515 | 156,770 | 101,911 | 1,299,946 | 108,329 | 3,552 |
| 2011 | 87,114 | 81,538 | 85,229 | 99,051 | 74,063 | 99,897 | 87,727 | 101,421 | 104,816 | 101,352 | 110,513 | 106,413 | 1,139,134 | 94,928 | 3,112 |
| 2012 | 94,984 | 110,048 | 115,902 | 88,463 | 101,503 | 86,145 | 104,658 | 102,195 | 101,295 | 109,730 | 125,299 | 103,785 | 1,244,007 | 103,667 | 3,399 |
| 2013 | 117,719 | 85,419 | 88,245 | 102,255 | 103,486 | 107,684 | 103,673 | 119,535 | 89,915 | 129,164 | 127,491 | 103,623 | 1,278,210 | 106,517 | 3,492 |
| 2014 | 141,208 | 100,721 | 124,257 | 83,088 | 97,645 | 100,949 | 106,851 | 114,966 | 106,730 | 119,904 | 128,337 | 92,389 | 1,317,045 | 109,754 | 3,598 |
| 2015 | 101,771 | 115,660 | 122,897 | 102,075 | 104,131 | 131,166 | 122,670 | 150,948 | 114,705 | 150,706 | 145,675 | 116,235 | 1,478,638 | 123,220 | 4,040 |
| 2016 | 115,407 | 107,836 | 110,297 | 110,936 | 123,196 | 104,285 | 140,982 | 129,472 | 134,517 | 150,581 | 117,705 | 128,334 | 1,473,548 | 122,796 | 4,026 |
| 2017 | 127,206 | 114,396 | 116,889 | 101,931 | 130,301 | 120,224 | 113,993 | 113,993 | 124,516 | 124,817 | 131,561 | 123,618 | 1,443,443 | 120,287 | 3,944 |
| 2018 | 145,416 | 113,132 | 125,696 | 102,615 | 117,053 | 117,186 | 114,865 | 126,174 | 129,360 | 134,127 | 154,079 | 136,204 | 1,515,906 | 126,326 | 4,142 |
| 2019 | 127,594 | 107,752 | 115,746 | 121,228 | 125,951 | 107,682 | 121,616 | 127,709 | 131,953 | 148,622 | 137,570 | 123,672 | 1,497,094 | 124,758 | 4,090 |
| 2020 | | | | 119,568 | 102,608 | 91,242 | 123,069 | 100,534 | | | | | 537,020 | 107,404 | 3,521 |
| Ave | 129,727 | 103,237 | 105,679 | 106,749 | 105,457 | 112,218 | 109,699 | 122,697 | 116,878 | 126,235 | 134,483 | 110,984 | 1,384,044 | | |




Figure 2. Otjiwarongo historical water demand

Now, Otjiwarongo receives the water supply from Nam Water, however, due to the lack of water resources, the water supply is not sustainable and stable. In the informal settlement area, the condition is worse.

The average water demand by month varies around from 3,500 m³/d to 4,000 m³/d.

3.2 Existing Oxidation Pond in Otjiwarongo

Oxidation ponds are large, shallow ponds designed to treat various wastewaters naturally through the interaction of sunlight, bacteria, and algae. They are designed to reduce organic content and remove pathogens from wastewater. They are man-made depressions confined by earthen structures. Wastewater enters on one side of the pond and exits on the other side, after spending several days in the pond, during which treatment processes take place. There are often several ponds with different functions to reduce organic content and remove pathogens. In most ponds both bacteria and algae are needed in order to maximize the decomposition of organic matter and the removal of other pollutants.

Oxidation ponds are especially well suited for warm climates, because the intensity of sunlight and temperature that are needed for the treatment process. They cost less to build than other treatment facilities and can be considered as one of the cheapest wastewater treatments options in terms of maintenance.

However, Oxidation ponds do require relatively large areas, they emit odours that may be incommoding to close-by residential areas, and there is a risk of ground water contamination or overflow, especially when the pond is operating above its rated capacity.



Figure 3. Existing Oxidation Pond in Otjiwarongo



Figure 4. Lay out of Existing Oxidation Pond in Otjiwarongo

The existing oxidation pond in Otjiwarongo is located at North-western side of city, and the Figure 3 and 4 shows the current status and pipe line network in oxidation pond. As it is shown, there is enough unused space in the pond. Now in this Feasibility study, we are going to make locate the water recycling plant in the available area in the existing plant area.

Table 3. Result of water quality test

| | Value | Unit | Remarks |
|-------------------------------------|-------|------|---------|
| pH | 8.0 | Ms/m | |
| Conductivity | 151.3 | mg/l | |
| TDS | 1014 | mg/l | |
| Sodium as Na | 140 | mg/l | |
| Nitrate as N | 0.5 | mg/l | |
| Nitrite as N | 0.1 | mg/l | |
| Temperature (C) | 21.3 | | |
| COD | 105 | mg/l | |
| Oxygen Absorbed | 11.2 | mg/l | |
| BOD | 22 | mg/l | |
| P | 2.2 | mg/l | |
| Total Nitrogen as N | 43.0 | mg/l | |
| Ammonia as N | 2.6 | mg/l | |
| TSS | 17.0 | mg/l | |
| Fat, Oil & Grease as FOG | <0.10 | g/l | |

► **Date sample taken: 2018/4/17**

Otjiwarongo has almost 100 % sewerage network coverage. All of wastewater occurred in the city are gather in the existing oxidation pond, and the effluent water quality is shown in the above table. Even though the values of some categories are over the common standard such as BOD, the overall status of effluent quality is not so bad to use as an influent of water recycling plant which is being planned in the feasibility study.




Figure 5. Sewerage Network in Otjiwarongo

3.3 Water recycling plant (Component 1)




Figure 6. water treatment process for component 1

After the communication with local authorities, the location of component 1 was planned at the next to existing oxidation pond. This location has advantage to receive the treated wastewater as influent of component 1.

The main process of plant consists of UF and RO with the capacity of 100 m³/day. The beneficiaries of this plant shall be from 500 to 1,000 people as per the unit water demand. In case of 100 LPCD, it will be 1000 people of beneficiaries. Considering the unstable power supply, Photovoltaics is applied as power sources together with ESS. The plant will be operated 10 hrs a day. We have applied 2 places of kiosk for the distribution of treated tap water and 5 km of pipe line. However, due to the covid-19, the field survey was not implemented. This kiosk items and the length of pipe line can be changed during the implementation stage based on the field survey within the available budget. The total estimated construction cost is 5,359,131 USD including transportation cost and commissioning cost as shown below;

Table 4. Estimated construction cost for component 1

| | Specification | amount | (USD) |
|--------------------------|--|--------|------------------|
| Civil + Architect | W8m x L15m | 1 | 86,957 |
| Process | UF + RO =100m ³ /day=10m ³ /hr (10hr Operation) | 1 | 521,379 |
| Photovoltaics | PV (25kw) + ESS | 1 | 69,565 |
| Transportation | Packing + transportation (Duty free) | 1 | 52,174 |
| Installation | Process *0.3 | 1 | 156,522 |
| commissioning | 3 Month x 2 people | 6 | 58,261 |
| Kiosk | Kiosk | 2 | 13,913 |
| Distribution | 5 km | | 4,440,000 |
| Total | | | 5,359,131 |





Figure 7. Plane drawing of component 1

3.4 Grey water recycling (Component 2)



Greywater recycling plant named as component 2 shall be located at near the primary school. It will receive the used water from the school and hospital (if possible) and supply to the school again for toilet water after treatment. The MBR (Membrane Bio Reactor) and NF is the main process of this plant. The photovoltaics is also applied in component 2 considering unstable power supply condition.

The capacity of greywater recycling plant is 500 m³/day with the condition of 24hrs operation. The number of students in the school is not surveyed due to the covid-19, but generally speaking, it is assumed the 500 CMD is enough to supply water to one primary school. After field survey during the implementation stage, it will be decided to supply water to the hospital near school or not considering the capacity of the plant and available budget.

Table 5. Estimated construction cost for component 2

| | Specification | amount | USD |
|-----------------|--|--------|------------------|
| Civil Architect | W27m x L15m | 1 | 869,565 |
| Process | MBR + NF =500m ³ /day=21m ³ /hr (24hr operation) | 1 | 1,304,348 |
| Photovoltaics | PV (90kw) + ESS | 1 | 1,800,000 |
| Transportation | Packing + transportation Duty free condition | 1 | 173,913 |
| Installation | Process *0.3 | 1 | 391,304 |
| commissioning | 3 Month x 3 people | 9 | 87,391 |
| Total | | | 4,626,521 |




Figure 7. Plane drawing of component 2

The total construction cost is shown below;

| Category | Total | Component 1 | Component 2 |
|------------------------|-----------|-------------|-------------|
| Construction cost(USD) | 9,985,652 | 5,359,131 | 4,626,521 |

3.5 Financial Analysis (Component 1)

A. Basic Assumptions for Economic Feasibility Study

Table 6. Basic assumptions

| Category | Description | |
|-------------------------------|--------------------------|--|
| Project Duration | Reference date | Jan 1, 2020 |
| | Construction period | 6 months (Jan. ~ Jun. 2023) |
| | Operating period | 20 years (Jul. 2023 ~ Jun. 2043) |
| | Operation Days in a Year | Water Supply : 365 days |
| Total Investment Costs | Total Project Costs | 5,678,614 USD |
| | Total Investment Costs | 6,091,633 USD |
| Financing Structure | Funding ratio | Public Sector : 100.0 % Private Sector : - |
| | | |
| Revenues and Expenses | Operating Revenues | Water supply: 0.69 USD/ ton |
| | Operating Expenses | Labor cost, electric power cost, general expense, maintenance cost |
| Others | Corporate Tax | 32.0%(single tax rate) |
| | Inflation Rate | 3.0% assumed |
| | Exchange Rate | KRW/USD = 1,085.30 assumed |

B. B/C Ratio Analysis

The unit price of water supply at the level that can cover the operating expenses of this project was calculated at 0.69 USD/Tone, and the B/C Ratio at that price level was calculated at 1.00 on both before-tax and after-tax basis.

Table 7. B/C Ratio

| Category | Before Tax | After Tax |
|------------------|------------|-----------|
| B/C Ratio | 1.00 | 1.00 |

In this feasibility study, we show the result of financial analysis, and the detailed analysis result is described in the financial mechanism analysis report.

3.6 Financial Analysis (Component 2)

A. Basic assumptions for economic feasibility analysis

- Basic assumptions for economic feasibility analysis are as follows

Table 8. Basic Assumption

| Category | Description | |
|-------------------------------|--------------------------|--|
| Project Duration | Reference date | Jan 1, 2020 |
| | Construction period | 6 months (Jan. ~ Jun. 2023) |
| | Operating period | 20 years (Jul. 2023 ~ Jun. 2043) |
| | Operation Days in a Year | Water supply : 365 days |
| Total Investment Costs | Total Project Costs | 4,902,331 USD |
| | Total Investment Costs | 5,258,889 USD |
| Financing | Funding Ratio | Public sector : 100.0 % |
| | | Private sector : - |
| Revenue and cost | Revenues | Water supply: 0.41 USD/ ton |
| | Operating Expenses | Labor cost, electric power cost, general expense, maintenance cost |
| Other assumptions | Corporate Tax | 32.0%(single tax rate) |
| | Inflation Rate | 3.0% assumed |
| | Exchange Rate | KRW/USD = 1,085.30 assumed |

B. Analysis of B/C ratio

The unit price of water supply at the level that can cover the operating expenses of this project was calculated at 0.41 USD/m³, and the B/C Ratio at that price level was calculated at 1.00 on both before-tax and after-tax basis.

Table 9. B/C Ratio

| Category | Before Tax | After Tax |
|------------------|-------------------|------------------|
| B/C Ratio | 1.00 | 1.00 |

In this feasibility study, we show the result of financial analysis, and the detailed analysis result is described in the financial mechanism analysis report.